

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1210701

Product: Circuit Breaker

Type: LTN-UC (variants see Annex)

Rating: 230/400 V AC, 400 V AC, 220 V DC, 440 V DC, 0,3 - 63 A, 1, 2 poles

Ordering firm: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 212768-01/01 of: 13.12.2021

A sample of the product was found to be in conformity with:
ČSN EN 60898-1 ed.2:19, ČSN EN 60898-2 ed.2:07

Other data:

The validity of the certificate is limited to: 16.12.2024

17.12.2021

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



* C E R / 1 2 1 0 7 0 1 *

212768-01

Overview of circuit breakers type serie LTN-UC:

Characteristic B

-	LTN-UC-2B-2
-	LTN-UC-4B-2
-	LTN-UC-6B-2
-	LTN-UC-8B-2
-	LTN-UC-10B-2

Characteristic C

LTN-UC-1C-1	LTN-UC-1C-2
LTN-UC-2C-1	LTN-UC-2C-2
LTN-UC-4C-1	LTN-UC-4C-2
LTN-UC-6C-1	LTN-UC-6C-2
LTN-UC-8C-1	LTN-UC-8C-2
LTN-UC-10C-1	LTN-UC-10C-2
LTN-UC-13C-1	LTN-UC-13C-2
LTN-UC-16C-1	LTN-UC-16C-2
LTN-UC-20C-1	LTN-UC-20C-2
LTN-UC-25C-1	LTN-UC-25C-2
LTN-UC-32C-1	LTN-UC-32C-2
LTN-UC-40C-1	LTN-UC-40C-2
LTN-UC-50C-1	LTN-UC-50C-2
LTN-UC-63C-1	LTN-UC-63C-2

