

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

CERTIFICATE

No.: 1240146

Product: Circuit-breaker

Type: LVN (variants see Annex)

Rating: 80, 100, 125 A, 230/400 V AC, 400 V AC, characteristic B, C, D,
poles 1, 2, 3, 4

Ordering firm: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 240668-01/01 of: 08.04.2024

A sample of the product was found to be in conformity with:
ČSN EN 60898-1 ed. 2:2019

Other data:

The validity of the certificate is limited to: 15.04.2027

16.04.2024

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



240668-01

Circuit-breaker LVN

<p>LVN-80B-1 LVN-100B-1 LVN-125B-1 LVN-80C-1 LVN-100C-1 LVN-125C-1 LVN-80D-1 LVN-100D-1</p> <p>LVN-80B-1-CS LVN-100B-1-CS LVN-125B-1-CS LVN-80C-1-CS LVN-100C-1-CS LVN-125C-1-CS LVN-80D-1-CS LVN-100D-1-CS</p> <p>LVN-100B-2 LVN-80C-2</p> <p>LVN-100B-2-CS LVN-80C-2-CS LVN-100C-2-CS</p> <p>LVN-80B-3 LVN-100B-3 LVN-125B-3 LVN-80C-3 LVN-100C-3 LVN-125C-3 LVN-80D-3 LVN-100D-3</p>	<p>LVN-80B-3-CS LVN-100B-3-CS LVN-125B-3-CS LVN-80C-3-CS LVN-100C-3-CS LVN-125C-3-CS LVN-80D-3-CS LVN-100D-3-CS</p> <p>LVN-80B-4 LVN-100B-4 LVN-125B-4 LVN-80C-4 LVN-100C-4 LVN-125C-4 LVN-80D-4 LVN-100D-4</p> <p>LVN-80B-4-CS LVN-100B-4-CS LVN-125B-4-CS LVN-80C-4-CS LVN-100C-4-CS LVN-125C-4-CS LVN-80D-4-CS LVN-100D-4-CS</p> <p>LVN-100C-4-CS-Telasi LVN-125C-4-CS- Telasi</p>
---	---

