

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

CERTIFICATE

No.: 1240270

Product: Switch module

Type: MSK

Rating: 230 V AC, 12 V DC, AC-12, DC-12 (see enclosure)

Ordering firm: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 241164-01/01 of: 22.05.2024

A sample of the product was found to be in conformity with:
ČSN EN 60947-5-1 ed. 3:2018 cl. 8.2.4, 8.3.3.3, 8.3.3.4, 8.3.3.5.3, 8.3.3.5.6, 8.3.4, C.2,
ČSN EN 60947-1 ed. 4:2008+A1:2011+A2:2015 Annex C

Other data:

The validity of the certificate is limited to: 05.06.2027

06.06.2024

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



241164-01

Type series overview:

Design	Arrangement of contacts ¹⁾	Type	Rated current
Switch	10	MSK-10	16 A
Switch with red backlight	10	MSK-10-SC	16 A
Switch with green backlight	10	MSK-10-SE	16 A
Change-over switch	001	MSK-001-1X2	10 A
Change-over switch with intermediate position	001	MSK-001-102	6 A
Change-over switch with intermediate position without arrestment	001	MSK-001-1T2	6 A

¹⁾ Each digit indicates successively the number of make, break and break-make contacts.

