

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lísem 129/2, Troja, 182 00 Praha 8

## CERTIFICATE

No.: 1240324

**Product:** Switch-disconnector

**Type:** MSO

**Rating:** 32 - 63 A, 80 - 125 A, 250/440 V, 1 - 4 poles

**Ordering firm:** OEZ s.r.o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Manufacturer:** OEZ s.r.o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Trade mark:**

**The test results are stated in the test-report No.:** 241162-01/01 of: 24.06.2024

**A sample of the product was found to be in conformity with:**  
ČSN EN 60947-3 ed. 4:2021

**Other data:**

**The validity of the certificate is limited to:** 30.06.2027

01.07.2024

Prague

Mgr. Miroslav Sedláček  
Head of Certification Body



241162-01