

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

CERTIFICATE

No.: 1240405

Product: Fuse-disconnector

Type: OPT22 (see Annex)

Rating: 63 A, AC 1500 V, DC 1500 V, AC 20 B, DC 20 B, IP20

Ordering firm: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 232902-01/01 of: 28.12.2023

A sample of the product was found to be in conformity with:
ČSN EN IEC 60947-3 ed. 4:2021

Other data:

The validity of the certificate is limited to: 20.08.2027

21.08.2024

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



232902-01

Enclosure to Certificate No. 1170667

OPT 22/1	fuse disconnecter 1-pole
OPT 22/2	fuse disconnecter 2-pole
OPT 22/3	fuse disconnecter 3-pole
OPT 22/4	fuse disconnecter 4-pole
OPT 20	fuse disconnecter 1-pole
OPT 22-1-S	fuse disconnecter 1-pole with signalling
OPT 22-2-S	fuse disconnecter 2-pole with signalling
OPT 22-3-S	fuse disconnecter 3-pole with signalling
OPT 22-4-S	fuse disconnecter 4-pole with signalling

