

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

CERTIFICATE

No.: 1240387

Product: Residual current circuit breakers

Type: OLI, typ F (see Annex)

Rating: AC 230 V, 50/60 Hz, I_n : 6, 10, 13, 16, 20, 25, 32, 40 A,
 I_{res} : 0,03 A, I_{cn} : 10 kA, char. B, C

Ordering firm: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 240905-02/01 of: 31.07.2024

A sample of the product was found to be in conformity with:
ČSN EN 61009-1 ed. 3:2013+A1:2015+A2:2015 +A11:2016+A12:2017+A13:2022,
ČSN EN 61009-2-1:97+A11:99, ČSN EN 62423 ed. 2:2013+A11:22+A12:23

Other data:

The validity of the certificate is limited to: 06.08.2027

07.08.2024

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



240905-02

Typová řada/Type series OLI - 10 kA, typ F:

OLI-6B-1N-030F-K
OLI-10B-1N-030F-K
OLI-13B-1N-030F-K
OLI-16B-1N-030F-K
OLI-20B-1N-030F-K
OLI-25B-1N-030F-K
OLI-32B-1N-030F-K
OLI-40B-1N-030F-K
OLI-6C-1N-030F-K
OLI-10C-1N-030F-K
OLI-13C-1N-030F-K
OLI-16C-1N-030F-K
OLI-20C-1N-030F-K
OLI-25C-1N-030F-K
OLI-32C-1N-030F-K
OLI-40C-1N-030F-K

