

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

CERTIFICATE

No.: 1240508

Product: Fuse rails

Type: FSR 00,1,2,3 (see Annex)

Rating: 160 A, 250 A, 400 A, 630 A, 690 V AC

Ordering firm: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 232755-01/01 of: 29.10.2024

A sample of the product was found to be in conformity with:
ČSN EN 60269-1 ed. 3:2008+A1:2010+A2:2015, ČSN 35 4701-2 ed. 3:2014+Z1:2023

Other data:

The validity of the certificate is limited to: 04.11.2027

05.11.2024

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



232755-01

Typové označení Type marking	Velikost Size	I_e	U_e	Rozteč přípojníc Spacing
FSR00-3D-F	00	160 A	690 V a.c./ 690 V d.c.	185 mm
FSR00-3D-FC	00	160 A	690 V a.c./ 690 V d.c.	185 mm
FSR00-3D-FC-M05	00	160 A	690 V a.c./ 690 V d.c.	185 mm
FSR00-3D-FC-M1	00	160 A	690 V a.c./ 690 V d.c.	185 mm
FSR00-3D-FC-M05C	00	160 A	690 V a.c./ 690 V d.c.	185 mm
FSR00-3D-FC-RM1	00	160 A	690 V a.c./ 690 V d.c.	185 mm
FSR1-3K-LM	1	250 A	690 V a.c./ 690 V d.c.	185 mm
FSR1-3K-LW	1	250 A	690 V a.c./ 690 V d.c.	185 mm
FSR1-3K-LL	1	250 A	690 V a.c./ 690 V d.c.	185 mm
FSR2-3K-LM	2	400 A	690 V a.c./ 690 V d.c.	185 mm
FSR2-3K-LW	2	400 A	690 V a.c./ 690 V d.c.	185 mm
FSR2-3K-LL	2	400 A	690 V a.c./ 690 V d.c.	185 mm
FSR2-3P-LW	2	400 A	690 V a.c./ 690 V d.c.	185 mm
FSR2-3P-LL	2	400 A	690 V a.c./ 690 V d.c.	185 mm
FSR3-3K-LM	3	630 A	690 V a.c./ 690 V d.c.	185 mm
FSR3-3K-LW	3	630 A	690 V a.c./ 690 V d.c.	185 mm
FSR3-3K-LL	3	630 A	690 V a.c./ 690 V d.c.	185 mm

